



TAMILNADU TEST HOUSE PRIVATE LIMITED

www.tamilnadutesthouse.com

TEST REPORT

TEST REPORT NO: TNTH/M-3971/2023-24

DATE:03.10.2023

SAMPLE SUBMITTED BY CUSTOMER

SAMPLE SUBMITTED BY	M/s Crescent Institute of Science & Technology
ADDRESS	Vandalur, Chennai-600 048
SAMPLE DESCRIPTION	STP Raw Water- Men's Hostel
SAMPLE QUANTITY	2 Litre
PACKING	In Plastic Can
SAMPLE RECEIVED ON	13.09.2023
ANALYSIS STARTED ON	13.09.2023
ANALYSIS COMPLETED ON	03.10.2023

Terms and Conditions

This report in full or in part shall not be published, advertised, used for any legal action, unless prior permission has been secured. This test report pertains only for the sample tested and such samples are retained for 7 days (in case of perishable) and 15 days for all other samples. In case of Complaint received from customers sample will be kept for 30 days. The samples from regulatory bodies are to be retained as specified. This document cannot be reproduced except in full, without prior written approval of the company.

For Tamilnadu Test House Private Limited

Managing Director

Page 1 of 2



TAMILNADU TEST HOUSE PRIVATE LIMITED

www.tamilnadutesthouse.com

TEST REPORT

TEST REPORT NO: TNTH/M-3971/2023-24

DATE:03.10.2023

SAMPLE SUBMITTED BY CUSTOMER

SAMPLE DESCRIPTION STP Raw Water- Men's Hostel

ANALYSIS STARTED ON 13.09.2023

ANALYSIS COMPLETED ON 03.10.2023

S. NO	PARAMETERS	METHOD	UNITS	RESULTS	LIMITS
1	pH @ 25°C	IS 3025 (P11): 1983 (Reaff.2017)	-	7.25	5.5 to 9.0
2	Total Dissolved solids	IS 3025 (P16) :1984 (Reaff. 2017)	mg/L	1336	NMT 500
3	Total Suspended solids	IS 3025 (P17) : 1984 (Reaff. 2017)	mg/L	66	NMT 50
4	Chloride as Cl ⁻	IS 3025 (Part 32)-1988 (R.2009)	mg/l	329.40	NA
5	Sulphate as SO ₄	IS 3025 (Part 24)-1986 (R.2009)	mg/l	81.86	NA
6	Biological Oxygen Demand @ 27°C	IS 3025 (P 44) : 1993 (Reaff. 2019)	mg/L	75	NMT 20
7	Chemical Oxygen Demand	IS 3025 (P 58) : 2006 (Reaff. 2017)	mg/L	201.0	NMT 250
8	Oil and Grease	IS 3025 (P 39) : 1991 (Reaff.2019)	mg/L	BQL(LOQ:1.0)	NMT 10

BQL- Below Quantification Limit, LOQ- Limit of Quantification

*** END OF THE REPORT ***

For Tamilnadu Test House Private Limited

Verified By

Authorised Signatory

Page 2 of 2