



# Bio Green Lab Services

Govt. Registered (UAN No :TN02A0155256)  
An ISO 9001 : 2015 Certified Laboratory

Mobile No. : 99622 30642

94440 07584



REF: BGLS/AUG-792/EC/25-26

AUGUST 13, 2025

## ANALYSIS REPORT

Client Name	M/S.B.S.Abdur Rahman Crescent Institute of Science & Technology.
Client Address	Chennai.
Sample Mark	Campus Canteen
Sources Of Water	Well Water
Date of Sample Received	12.08.2025
Date of Sample Commenced	13.08.2025
Date of Sample Completed	13.08.2025

S.No	Parameters	Unit	Results	Test Method (APHA 23 <sup>rd</sup> Edition 2017)	Limits as per IS:10500 -2012 Standards	
					Acceptable Limit	Permissible Limit in the absence of alternate source
01	Physical Appearance	-	Turbid	-	-	-
02	Color	Hazen	1.0	2120 B	5	15
03	Odour	-	Agreeable	2150 B	Agreeable	Agreeable
04	pH at 25°C	-	7.44	4500 H * B	6.5 – 8.5	6.5 – 8.5
05	Turbidity	NTU	1.2	2130 B	1	5
06	Electrical Conductivity at 25°C	Micromhos/ cm	1382	2510 B	-	-
07	Total Suspended Solids(TSS)	mg/l	2.0	2540 D	-	-
08	Total Dissolved Solids(TDS)	mg/l	898	2540 C	500	2000
09	Total Alkalinity(as CaCO <sub>3</sub> )	mg/l	160	2320 B	200	600
10	P-Alkalinity (as CaCO <sub>3</sub> )	mg/l	Nil	2320 B	-	-
11	Total Hardness (as CaCO <sub>3</sub> )	mg/l	340	2340 C	200	600
12	Calcium Hardness (as CaCO <sub>3</sub> )	mg/l	190	3500 - Ca B	-	-
13	Magnesium Hardness (as CaCO <sub>3</sub> )	mg/l	150	3500 - Mg B	-	-
14	Calcium (as Ca )	mg/l	77.5	3500 B	75	200
15	Magnesium (as Mg)	mg/l	36.5	2340 C	30	100
16	Total Iron (as Fe)	mg/l	0.1	3500 Fe-B	1.0	1.0





# Bio Green Lab Services

Govt. Registered (UAN No : TN02A0155256)  
An ISO 9001 : 2015 Certified Laboratory

Mobile No. : 99622 30642  
94440 07584



REF: BGLS/AUG-792/EC /25-26

AUGUST 13, 2025

S.NO	Parameters	Unit	Results	Test Method (APHA 23 <sup>rd</sup> Edition)	Limits as per IS: 10500 - 2012 Standards	
					Acceptable Limit	Permissible Limit in the absence of alternate source
17	Chloride (as Cl <sup>-</sup> )	mg/l	241	4500 Cl B	250	1000
18	Sulphate (as SO <sub>4</sub> <sup>-</sup> )	mg/l	153	4500 SO <sub>4</sub> <sup>2-</sup> E	200	400
19	Carbonate Hardness (as CaCO <sub>3</sub> )	mg/l	160	2340 A	-	-
20	Non Carbonate Hardness (as CaCO <sub>3</sub> )	mg/l	180	2340 A	-	-
21	Silica Reactive (as SiO <sub>2</sub> )	mg/l	15.9	4500 SiO <sub>2</sub> C	-	-
22	Free Residual Chlorine	mg/l	Nil	4500 Cl B	0.2	**1

BDL: Below Detection Limit

## Remarks:

The above submitted water sample Does Not Comply with drinking water specification as per IS: 10500: 2012 respects to the above test conducted.

\*\*\*End of Test Report\*\*\*



Authorized Signatory

## Note:

1. Reports shall not be reproduced, except in full, without the written approval of the laboratory
2. Details as furnished by the client and Samples as supplied by the client.
3. Any clarifications / complaints of the report should be made in writing within 2 days from the date of test report.
4. Unless informed by the client the samples will not be retained for more than 7 days from the date of issue of this report.